

TRANSPORTATION CHECKLIST

Land Disturbance Permit

Completed by: _____.

Date: _____.

Provided column for Developer/Engineer

Checked column for Reviewer(County)

Checked by: _____.

Date: _____.

Item No.	Item	Provided	Checked	Remarks/Comments
1	Vicinity map showing overall location with North Arrow			
2	All sheets of plans must be sealed by a professional engineer or state landscape currently registered in Georgia			
3	Centerline street profiles, rights-of-way street profiles, centerline percent of grade, finish grade elevation every 100 feet, vertical curve information, horizontal curve data, stations at centerline street intersections, radii, etc.			
4	Proposed typical street cross sections showing thicknesses, materials type, shoulder width and slope, typical waterway section cut and fill side slopes			
5	Right-of-way (existing & proposed for roads and internal streets)			
6	Right-of-way (reserved or dedicated for public use and/or future public improvements)			
7	Deceleration/acceleration lanes lane length plus taper length (150 feet lane and 50 foot taper std)			
8	Additional profiles as may be required on existing county roads when roads abut or adjoin proposed streets.			
9	When entrances from state roads are proposed, an approved entrance plan from the Georgia Department of Transportation is required.			
10	Location of sidewalks & ADA ramps, if required Typical section of the sidewalk detail needed			
11	Details of other transportation imprvmts needed e.g. traffic signals, sight distance issues, etc			

Item No.	Item	Provided	Checked	Remarks/Comments
12	Provide the following note on the plans: "Necessary signs, barricades, lights and other traffic control devices as may be necessary for the protection and safety fo the public shall be provided in accordance with the Manual on Uniform Traffic Control Devices (MUTCD) and shall be maintained throughout the widening of and construction on Rockdale County roads and streets "			
13	Traffic calming devices, e.g. easeabouts, traffic circle, roundabouts, etc. shall be shown on the plans per Rockdale County standards-Details are to be included			
14	All proposed traffic signs and pavement markings shall be shown on the plans, including sizes and types			
15	Topography and contour lines (existing/proposed)			
16	Existing/proposed roads/streets and street names on all plan sheets			
17	Fully bituminous coated corrugate metal pipe shall not be used in any installation if the storm sewer is to be maintained by Rockdale County			
18	Easements - no access, ingress/egress & construction			
19	Driveway access available on internal streets			
20	Sight distance available at proposed road/street openings onto public roads/streets - provide note on plans to indicate "Minimum or better AASHTO sight distance provided by engineer of record"			
21	Angle of road intersections shown (90 degrees unless otherwise approved)			
22	Existing/proposed utility location and sizes			
23	Standard Utility Placement detail included			
24	Parking space dimensions (9'x19' min.std -- 13'x19' min. handicap)			
25	Aisle width of parking (24' for two-way & 18' for one-way)			
26	Handicap parking - spaces/signs/ADA ramps			
27	Traffic flow in parking area - directional arrows			