

April 22, 2013

Alan Anderson
NPDES Enforcement Section
Arkansas Department of Environmental Quality
5301 North Shore Dr
North Little Rock, Arkansas 72118

RE: Storm water Blending April 10, 2013 thru April 14, 2013
Russellville City Corporation Pollution Control Works
NPDES Permit No. AR0021768 AFIN 58-0015

Dear Mr. Anderson:

In an attempt to save the City Corporation Pollution Control Works from becoming hydraulically overloaded, we would provide the following data for the storm water blending event that occurred at the Pollution Control Works, Wednesday April 10, 2013 and ending Sunday April 14, 2013. As was conveyed in the initial report this blending was due to excessive storm events experienced in the area.

We would offer the following results:

Gallons blended: 18,606,500 gallons estimated.

Wednesday, April 10, 2013

Total Suspended Solids	136.0 mg/l	CL2	0.02 mg/l
Dissolved Oxygen	6.0 mg/l	pH	6.81
Ammonia	7.86 mg/l	BOD	>47.1 mg/l
Fecals	1,450/100ml		

Thursday, April 11, 2013

Total Suspended Solids	248.0 mg/l	CL2	0.02 mg/l
Dissolved Oxygen	5.7 mg/l	pH	6.37
Ammonia	7.21 mg/l	BOD	>45.3 mg/l
Fecals	9,400/100ml		

Friday, April 12, 2013

Total Suspended Solids	68.0 mg/l	CL2	0.09 mg/l
Dissolved Oxygen	6.85 mg/l	pH	6.37
Ammonia	4.02 mg/l	BOD	43.5 mg/l
Fecals	5,500/100ml		

Sincerely,

Steve Mallett
General Manager

cc: Ricky Biffle
Randy Bradley
File