



NOTES: CONCRETE BASE AND BLOCKING MATERIAL SHALL NOT BLOCK NOR OBSTRUCT HYDRANT DRAIN AS SHOWN IN AWWA MANUAL M 17

ALL MATERIALS TO BE MADE IN U.S.A.

NO SIDEWALKS SHALL BE CONSTRUCTED WITHIN 2 FEET OF HYDRANT

ALL BOLTS BELOW GRADE SHALL BE STAINLESS STEEL

## STANDARD FIRE HYDRANT INSTALLATION

CITY OF OTTAWA

DRG. 4

OCTOBER 15, 2018