

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 49-51-1490141 Name of Facility: Avant Garde Academy Address: 2880 N Orange Blossom Trail City, Zip: Kissimmee 34744 Type: Public Charter School Owner: Charter OC Kissimmee Holdings LLC Person In Charge: Charter OC Kissimmee Holdings LLC Phone: (321) 697-3800 PIC Email:	Correct By: None Re-Inspection Date: None
--	--

Inspection Information

Purpose: Routine Inspection Date: 4/26/2019	Begin Time: 10:45 AM End Time: 11:35 AM
--	--

Additional Information

FEMALES 257 MALES 319	CENSUS 576
--------------------------------------	------------------

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION <input checked="" type="checkbox"/> 1. School Site <input checked="" type="checkbox"/> 2. Playground, Equip & Athletic Fields* <input checked="" type="checkbox"/> 3. Athletic & Playground Equipment BUILDING CONST/MAINT. <input checked="" type="checkbox"/> 4. Construction <input checked="" type="checkbox"/> 5. Maintenance & Repair <input checked="" type="checkbox"/> 6. Lighting Standards <input checked="" type="checkbox"/> 7. Heating, Ventilation, A/C Standards <input checked="" type="checkbox"/> 8. Natural Ventilation <input checked="" type="checkbox"/> 9. Mechanical Ventilation SANITARY FACILITIES <input checked="" type="checkbox"/> 10. Provided/Accessible/Separation	<input checked="" type="checkbox"/> 11. Group Toilet Rooms <input checked="" type="checkbox"/> 12. Toilet Facilities <input checked="" type="checkbox"/> 13. Handwashing Facilities <input checked="" type="checkbox"/> 14. Soap Dispensers <input checked="" type="checkbox"/> 15. Shower Facilities <input checked="" type="checkbox"/> 16. Showers Water Temperatures WATER SUPPLY <input checked="" type="checkbox"/> 17. Approved Source <input checked="" type="checkbox"/> 18. Drinking Fountains LIQUID WASTE & WASTE WATER <input checked="" type="checkbox"/> 19. Sewage Disposal <input checked="" type="checkbox"/> 20. Solid Waste PEST CONTROL	<input checked="" type="checkbox"/> 21. Pest Control SAFETY <input checked="" type="checkbox"/> 22. First Aid Kit DIAPER CHANGING STATION <input checked="" type="checkbox"/> 23. Sanitizers <input checked="" type="checkbox"/> 24. Changing Station & Mats <input checked="" type="checkbox"/> 25. Hand Sink <input checked="" type="checkbox"/> 26. Garbage Can ANIMAL HEALTH & SAFETY <input checked="" type="checkbox"/> 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES <input checked="" type="checkbox"/> 28. Maintenance/Complaint <input checked="" type="checkbox"/> 29. Other
--	--	---

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

General Comments

No violations observed.
Email Address(es): kyarbrough@avantgardeacademy.org

Inspector Signature:

Client Signature: