



NOTES:

1. WHERE TRENCH PASSES THROUGH EXISTING PAVEMENT THE PAVEMENT SHALL BE CUT ALONG A NEAT VERTICAL LINE A MINIMUM OF 12" FROM THE EDGE OF THE TRENCH OPENING. WHERE NEAT LINE IS LESS THAT 3' FROM EDGE OF EXISTING PAVEMENT OR CURB AND CUTTER SECTION, REMOVE AND REPLACE ENTIRE PAVEMENT SECTION BETWEEN TRENCH AND EDGE OF PAVEMENT.
2. SEE CONTRACT SPECIAL PROVISIONS FOR ANY MODIFICATIONS TO STANDARD TRENCH MATERIALS AND/OR OTHER TRENCH DESIGN FEATURES.
3. REFERENCE O.S.H.A. SAFETY AND HEALTH REGULATIONS FOR CONSTRUCTION, SECTION 1926.652.
4. ONLY UNDISTURBED NATIVE SOIL OR 3/4" WASHED ROCK ALLOWED UNDER PIPE.

DETAIL NO.: BSWSD: 22-02A	BIG SKY WSD 363 STANDARD DRAWING	SCALE: NONE	TYPICAL BIG SKY UTILITY TRENCH DETAILS - 1	DATE: FEBRUARY 2010
				LAST REVISION: JANUARY 2020
				CROSS REFERENCE WITH: MPW-6-NO. 02221-1