



**NOTES:**

1. ALL PARTS MUST BE APPROVED BY BSWSD 363.
2. ALL WATER SERVICE LINES SHALL BE A MINIMUM OF 1" Ø AND SHALL BE CLASS SDR-7, PE-4710 POLYETHYLENE PRESSURE PIPE MINIMUM 250 PSI PRESSURE RATING. PIPE SHALL BE PERFORMANCE PIPE A DIVISION OF CHEVRON PHILLIPS CHEMICAL COMPANY DRISCOPEX 5100 SERIES ULTRALINE HDPE PIPE AND TUBING OR A BSWSD APPROVED EQUAL.
3. PLACE 6" OF 3/4" WASHED ROCK BOTH BELOW AND ABOVE WATER SERVICE.
4. BSWSD 363 RECOMMENDS SLEEVING CURB STOP BOX (RISER) WITH 4" SDR 35 TO KEEP RISERS LEVEL.
5. ALL SERVICE LINES SHALL BE INSTALLED WITH #12-THHN LOCATE WIRE.

**DETAIL NO.:**

**BSWSD:  
26-06**

**BIG SKY WSD 363  
STANDARD DRAWING**

**SCALE:**  
NONE

**WATER SERVICE LINE**

**DATE:**

FEBRUARY 2010

**LAST REVISION:**

JANUARY 2020

**CROSS REFERENCE WITH:**

N/A