



**NOTES:**

1. BLOW-OFF HYDRANT WITH HORIZONTAL INLET SHALL BE NON-FREEZING, FULL DRAIN TYPE WITH A MINIMUM 7-FOOT BURY DEPTH. THESE HYDRANTS SHALL BE FURNISHED WITH A HORIZONTAL INLET, A NON-TURNING OPERATING ROD, AND SHALL OPEN TO THE LEFT. ALL OF THE WORKING PARTS SHALL BE OF BRONZE-TO-BRONZE DESIGN, AND BE SERVICEABLE FROM ABOVE GRADE WITH NO DIGGING. THE OUTLET SHALL ALSO BE BRONZE AND BE 2-1/2" NST NOZZLE. HYDRANTS SHALL BE LOCKABLE TO PREVENT UNAUTHORIZED USE.
2. ALL PARTS MUST BE APPROVED BY BSWSD 363.
3. PLACE 6" OF 3/4" WASHED ROCK BOTH BELOW AND ABOVE WATER SERVICE.
4. BSWSD 363 RECOMMENDS SLEEVING CURB STOP BOX (RISER) WITH 4" SDR 35 TO KEEP RISERS LEVEL.

<b>DETAIL NO.:</b>  <b>BSWSD:</b> <b>26-07A</b>	<b>BIG SKY WSD 363</b> <b>STANDARD DRAWING</b>	<b>SCALE:</b>  NONE	TYPICAL 2" BLOW-OFF HYDRANT	<b>DATE:</b> FEBRUARY 2010
				<b>LAST REVISION:</b> JANUARY 2020
				<b>CROSS REFERENCE WITH:</b> N/A