



NOTES:

1. GATE VALVE SHALL CONFORM TO AWWA C-500 OR C-509
2. VALVE BOXES SHALL BE PLUMB AND CENTERED DIRECTLY OVER THE VALVE NUT.
3. VALVE BOX TOP SHALL BE ADJUSTED TO MEET FINISHED GRADE.
4. VALVE EXTENSION SHALL BE INSTALLED WITH CENTERING RING AND WITHIN 18" OF FINISH GRADE. EXTENSIONS SHALL NOT BE ATTACHED TO VALVE.
5. ALL PARTS MUST BE APPROVED BY BSWSD 363.
6. THRUST BLOCKS MAY BE REQUIRED AT THE DISCRETION OF BSWSD 363.

DETAIL NO.: BSWSD: 26-15	BIG SKY WSD 363 STANDARD DRAWING	SCALE: NONE	GATE VALVE & VALVE BOX INSTALLATION	DATE: FEBRUARY 2010
				LAST REVISION: JANUARY 2020
				CROSS REFERENCE WITH: N/A