



- NOTES:**
1. ALL SERVICE LINES MUST BE SLEEVED FROM POINT OF ENTRY TO MECHANICAL ROOM OR ENTRY LOCATION.
 2. EACH UNIT MUST HAVE ACCESS TO THEIR RESPECTIVE METER.
 3. MULTIPLE UNITS MAY BE SERVED BY ONE SERVICE LINE IF A SHARED MECHANICAL ROOM WITH PERMANENT OUTSIDE ACCESS EXISTS.
 4. EACH UNIT MUST HAVE ITS OWN METER AND BACKFLOW PREVENTION.
 5. ALL PARTS MUST BE APPROVED BY BSWSD 363.

DETAIL NO.:	BIG SKY WSD 363 STANDARD DRAWING	SCALE:	WATER SERVICES WITH A COMMON TRENCH FOR MULTI-PLEX UNITS	DATE:	FEBRUARY 2010
BSWSD:		NONE		LAST REVISION:	JANUARY 2020
26-27				CROSS REFERENCE WITH:	N/A