



- NOTES:**
1. ALL JOINTS BETWEEN MANHOLE SECTIONS, ADJUSTING RINGS, MANHOLE RING & TOP SECTION, AND AROUND WATER PIPE INLET AND OUTLET WITHIN MANHOLE SHALL BE WATERTIGHT. JOINTING MATERIAL SHALL BE "RAM-NEK" OR EQUAL FOR ALL JOINTS EXCEPT BETWEEN SEWER PIPE AND MANHOLE WALL WHERE LOK, WATERTIGHT BOOTS SHALL BE USED. GROUTING BETWEEN JOINTS WILL NOT BE ALLOWED.
  2. ALL PARTS MUST BE APPROVED BY BSWSD 363.

|   |   |                           |  |                                       |
|---|---|---------------------------|--|---------------------------------------|
| <b>DETAIL NO.:</b><br><br><b>BSWSD:</b><br><b>26-31</b> | <b>BIG SKY WSD 363</b><br><b>STANDARD DRAWING</b> | <b>SCALE:</b><br><br>NONE | AIR RELEASE VALVE AND<br>VAULT<br>8" - 12" Ø WATER MAINS | <b>DATE:</b><br>FEBRUARY 2010         |
|   |   |                           |  | <b>LAST REVISION:</b><br>MAY 13, 2010 |
|   |   |                           |  | <b>CROSS REFERENCE WITH:</b><br>N/A   |