

**SCS Global Services** does hereby certify that an independent assessment has been conducted on behalf of:

## Cintek System Inc, Dba Carlton Hardwood Flooring

2410 South Sierra Drive, Compton, CA, United States

For the following product(s):

### Vinyl Tile:

Prime Waterproof Vinyl Flooring (WPC) (maximum thickness 12mm), Prime Essential Waterproof Vinyl (maximum thickness 5.5mm), Prime Premium Vinyl Flooring (WPC) (maximum thickness 12mm), Coastal Plank (SPC) (maximum thickness 5.5 mm), Newport Collection Vinyl Flooring (SPC) (maximum thickness 5.5 mm), Cascade Choice (SPC) (maximum thickness 5.5mm),

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

### FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-04143

Valid from: June 24, 2020 to May 31, 2021

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ISO/IEC 17065  
Product Certification Body  
#0821



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President

SCS Global Services

2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA