

## Work Orders: Custom Report

ID	Category	Location	Status	Date/Time Submitted	Submitted By	Description	Actual Cost	Labor Hours	Date/Time Completed	Completed By	Date/Time Closed	Closed By
61	Lighting	Hangar	Work Complete	2019-10-31 08:56	Garry Parker	Hangar 4-C : Light isn't working.	\$ 0.00	0.0	2019-11-20 00:00	Garry Parker		
62	Electrical	Hangar	Work Complete	2019-10-31 08:58	Garry Parker	Hangar 16-H Light is not working.	\$ 0.00	0.0	2019-11-20 00:00	Garry Parker		
63	Lighting	Hangar	Work Complete	2019-10-31 09:01	Garry Parker	Hangar 5-D: Light is not working.	\$ 0.00	0.0	2019-12-30 00:00	Garry Parker		
64	Door/Gate	Hangar	Work Complete	2019-10-31 09:04	Garry Parker	Hangar 4-C: Door is hard to open.	\$ 0.00	0.0	2020-02-03 00:00	Garry Parker		
65	Door/Gate	Hangar	Work Complete	2019-10-31 09:15	Garry Parker	Hangar 5-F New door seal needs to be adjusted as water is still entering the hangar when it rains.	\$ 0.00	0.0	2019-11-13 00:00	Garry Parker		
67	Lighting	Hangar	Work Complete	2019-11-05 09:23	Garry Parker	Hangar 21 : several exterior lights are out.	\$ 0.00	0.0	2019-11-14 00:00	Garry Parker		
69	Wildlife	Hangar	Work Complete	2019-11-06 08:19	Garry Parker	Hangar 11 PIGEONS, scheduled hangar entry for November 8th. Email notification sent to tenant John Walden on Friday, November 1st.	\$ 0.00	0.0	2019-11-14 00:00	Garry Parker		
72	Lighting	Hangar	Work Complete	2019-11-20 09:07	Garry Parker	Hangar 4B no Light is working	\$ 0.00	0.0	2019-12-03 00:00	Garry Parker		
73	Roof	Hangar	Work Complete	2019-11-20 12:22	Garry Parker	Hangar 14D Roof is leaking	\$ 0.00	1.0	2020-03-06 00:00	Jose Aviles		
74	Roof	Hangar	Work Complete	2019-11-20 12:23	Garry Parker	Hangar 14E roof is leaking.	\$ 0.00	1.0	2020-03-06 00:00	Jose Aviles		
75	Roof	Hangar	Work Complete	2019-11-20 12:25	Garry Parker	Hangar 2C roof is leaking	\$ 0.00	3.0	2020-03-11 00:00	Jose Aviles		
76	Wildlife	Hangar	Work Complete	2019-11-22 16:17	Garry Parker	Hangar 14-A Pigeons have returned. Ensure ends of doors are closed off to prevent pigeon entry. Inspect hangar for signs of roosting locations and apply bird gel.	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles		
77	Facilities	Hangar	Work Complete	2019-11-22 16:22	Garry Parker	Hangar 7 (AJ Jain) back wall is rusted and water seeps in during rain. Clean and seal the bottom of the sheet metal wall at the outside rear of the hangar.	\$ 0.00	5.0	2020-05-26 00:00	Jose Aviles		
78	Door/Gate	Hangar	Work Complete	2019-11-22 16:25	Garry Parker	Hangar 1-B Door sticks and sheet metal is loose near the tracks.	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles		
79	Door/Gate	Hangar	Work Complete	2019-11-22 16:27	Garry Parker	Hangar 2-C door is sticking.	\$ 0.00	0.0	2020-07-15 00:00	Garry Parker		
80	Door/Gate	Hangar	In Progress	2019-11-22 16:31	Garry Parker	Hangar 11 bay 2 (John Walden) Thicker door stopper required. Weld in place. 1/4" flat bar should protrude an inch more than the current door stopper.	\$ 0.00	0.0				
81	Facilities	Hangar	Work Complete	2019-11-22 16:34	Garry Parker	Hangar 8-B back wall is extruding beyond the concrete pad because the angle iron frame is missing. Anchor new angle iron onto the concrete, attach the sheet metal.	\$ 0.00	2.0	2020-05-26 00:00	Jose Aviles		
82	Door/Gate	Hangar	Work Complete	2019-11-25 09:28	Garry Parker	Hangar 13 door (lower side) door stop weld is broken. needs to be re-enforced and re-welded.	\$ 0.00	0.0	2019-12-05 00:00	Garry Parker		
83	Door/Gate	Hangar	Work Complete	2019-11-25 09:37	Garry Parker	Hangar 11 Bay 5: Bottom door roller 3rd door on the left, interior roller. Roller is wobbly, unsteady, needs to be adjusted, repaired, or replaced.	\$ 0.00	0.0	2019-12-03 00:00	Garry Parker		

84	Door/Gate	Hangar	Work Complete	2019-11-25 09:43	Garry Parker	Hangar 2-D (Facing gate 6) RH door sagging. Nut is missing from I-bolt on the top.	\$ 0.00	0.0	2019-12-03 00:00	Garry Parker		
85	Roof	Hangar	Work Complete	2019-11-25 13:13	Garry Parker	Hangar 4 C gutter is sagging. Repair/ Readjust to straighten gutter so that water flows to the downspout.	\$ 0.00	0.0	2019-11-25 00:00	Garry Parker		
91	Facilities	Hangar	Work Complete	2019-12-03 16:47	Garry Parker	Hangar 16-A Metal flashing is hanging off the corner of the hangar; straighten and/or re-attach.	\$ 0.00	0.0	2019-12-12 00:00	Garry Parker		
92	Lighting	Hangar	Work Complete	2019-12-03 16:53	Michele Renfro	4D lights are out	\$ 0.00	0.0	2019-12-13 00:00	Garry Parker		
93	Door/Gate	Hangar	Work Complete	2019-12-03 16:59	Garry Parker	Hangar 17-A Sheet metal on side of the building is crumpled at the bottom; sheet metal on the door is bent and rubber seal is torn/missing. Straighten sheet metal and fabricate, install new rubber door seal.	\$ 0.00	0.0	2019-12-12 00:00	Garry Parker		
100	Lighting	Hangar	Work Complete	2019-12-06 15:48	Amber Clark	Hangar 7C: 3 out of 4 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	0.0	2020-01-02 00:00	Garry Parker		
101	Lighting	Hangar	Work Complete	2019-12-06 16:33	Amber Clark	Hangar 8A: 3 out of 4 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	0.0	2019-12-31 00:00	Garry Parker		
102	Lighting	Hangar	Work Complete	2019-12-06 16:34	Amber Clark	hangar 11: 3 out of 4 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	3.0	2020-05-27 00:00	Jose Aviles		
103	Lighting	Hangar	Work Complete	2019-12-06 16:35	Amber Clark	hangar 12: 1 out of 5 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	24.0	2020-06-08 00:00	Jose Aviles		
104	Lighting	Hangar	Work Complete	2019-12-06 16:35	Amber Clark	hangar 14C: exterior overhead lights missing (safety issue for aircraft and FBO)	\$ 0.00	0.0	2020-02-06 00:00	Garry Parker		
105	Lighting	Hangar	Work Complete	2019-12-06 16:36	Amber Clark	hangar 16C: exterior overhead lights are missing (safety issue for aircraft and FBO)	\$ 0.00	0.0	2020-02-03 00:00	Garry Parker		
106	Lighting	Hangar	Work Complete	2019-12-06 16:38	Amber Clark	hangar 16G: 2 out of 3 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	0.0	2020-02-03 00:00	Garry Parker		
107	Lighting	Hangar	Work Complete	2019-12-06 16:39	Amber Clark	hangar 18B: 2 out of 3 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	0.0	2020-01-03 00:00	Garry Parker		
108	Lighting	Hangar	Work Complete	2019-12-06 16:41	Amber Clark	hangar 18J: 2 out of 3 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	0.0	2020-01-03 00:00	Garry Parker		
110	Lighting	Hangar	Work Complete	2019-12-06 16:42	Amber Clark	hangar 21F: 2 out of 3 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	0.0	2019-12-12 00:00	Garry Parker		
112	Lighting	Hangar	Work Complete	2019-12-06 16:44	Amber Clark	hangar 57: 2 out of 3 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	0.0	2020-01-10 00:00	Garry Parker		
113	Lighting	Hangar	Work Complete	2019-12-06 16:46	Amber Clark	maintenance hangar: 2 out of 3 exterior overhead lights are out	\$ 0.00	0.0	2020-05-27 00:00	Jose Aviles		
115	Roof	Hangar	Work Complete	2019-12-09 13:05	Michele Renfro	17A roof has hole that is leaking into hangar	\$ 0.00	2.0	2020-03-16 00:00	Jose Aviles		
116	Other	Hangar	Work Complete	2019-12-09 13:06	Michele Renfro	17A leaking from back panel of hangar	\$ 0.00	2.0	2020-03-16 00:00	Jose Aviles		
117	Lighting	Hangar	Work Complete	2019-12-09 13:06	Michele Renfro	Hangar 4D lights are not working. Has some florescent and regular lights.	\$ 0.00	0.0	2019-12-13 00:00	Garry Parker		
118	Other	Hangar	Work Complete	2019-12-09 13:08	Michele Renfro	5D is leaking water into hangar on outside wall as well as under the door. Customer vacated hangar and needs to be fixed before a new tenant can move in.	\$ 0.00	4.0	2020-04-01 00:00	Jose Aviles		
119	Wildlife	Hangar	Work Complete	2019-12-09 13:09	Michele Renfro	15C Pigeon issues at present time	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles		
121	Other	Hangar	Work Complete	2019-12-09 13:12	Michele Renfro	8D has leak by left interior pole. Tenant has vacated the hangar and it needs to be fixed before new tenant can move in.	\$ 0.00	2.0	2020-04-02 00:00	Jose Aviles		
122	Wildlife	Hangar	In Progress	2019-12-09 13:13	Michele Renfro	16H pigeons in hangar	\$ 0.00	0.0				

123	Door/Gate	Hangar	Work Complete	2019-12-09 13:16	Michele Renfro	H21 missing top portion of door seal.	\$ 0.00	9.0	2020-09-08 00:00	Jose Aviles		
124	Door/Gate	Hangar	Work Complete	2019-12-09 13:18	Michele Renfro	16A outside panel on corner has missing screws. Screws need to be replaced to keep the panel from blowing off the side of hangar.	\$ 0.00	0.0	2020-01-22 00:00	Garry Parker		
126	HVAC	Hangar	In Progress	2019-12-10 08:38	Michele Renfro	Office beside 15F needs to have AC/Heating unit replaced and pan put under to catch the drainage water from dripping into the hangar.	\$ 0.00	0.0				
132	Door/Gate	Hangar	Work Complete	2019-12-12 08:53	Garry Parker	Hangar 3-A Sheet metal hanging off the building	\$ 0.00	0.0	2019-12-12 00:00	Garry Parker		
133	Lighting	Hangar	Work Complete	2019-12-13 10:07	Garry Parker	Hangar 15-A Exterior Lights out	\$ 0.00	0.0	2020-02-03 00:00	Garry Parker		
134	Lighting	Hangar	Work Complete	2019-12-13 10:14	Garry Parker	Hangar 16-D Exterior Lights are not working	\$ 0.00	0.0	2020-01-24 00:00	Garry Parker		
172	Door/Gate	Hangar	Work Complete	2020-01-02 13:04	Garry Parker	Hangar 7A (office) door needs a new bottom seal. Office gets wet when it rains.	\$ 0.00	0.0	2020-01-07 00:00	Garry Parker		
173	Door/Gate	Hangar	Work Complete	2020-01-02 14:30	Michele Renfro	Hangar 21J-water is leaking down off roof onto interior door frame causing rust to drip on aircraft both sides. Can we spray rustoleum paint on the red iron frame to make it so it will cover the rust. Customer has mentioned this several times in the commission meetings.	\$ 0.00	0.0	2020-02-03 00:00	Garry Parker		
174	Other	Hangar	In Progress	2020-01-02 14:31	Michele Renfro	9A water leaking into hangar. possible under doors, up through concrete and back wall	\$ 0.00	0.0				
175	Other	Hangar	In Progress	2020-01-02 14:31	Michele Renfro	9B water in hangar. possible coming up through concrete	\$ 0.00	0.0				
193	Lighting	Hangar	Work Complete	2020-01-06 10:11	Raymond Keeler	Hanger 16-F exterior light is out, was working on 01/02/2019.	\$ 0.00	2.0	2020-03-16 00:00	Jose Aviles		
248	Door/Gate	Hangar	In Progress	2020-01-21 08:59	Michele Renfro	14B left side door on top has door stop missing so the doors move freely. Bolt and plates need to be replaced so the left door will lock properly.	\$ 0.00	0.0				
278	Wildlife	Hangar	Work Complete	2020-01-27 08:14	Michele Renfro	7A has noticed where pigeons have started getting into hangar recently. They have never had an issue with this in the past. Jose: Assess and mitigate entry point.	\$ 0.00	0.0	2020-08-10 00:00	Garry Parker		
279	Other	Hangar	Work Complete	2020-01-27 08:34	Michele Renfro	15B needs to be cleaned from customer move out. Shelves in back of hangar can also be thrown out. Customer waiting to move in.	\$ 0.00	0.0	2020-01-29 00:00	Garry Parker		
280	Roof	Hangar	Work Complete	2020-01-27 08:35	Michele Renfro	7A back right corner has roof leak as well as back wall.	\$ 0.00	0.0	2020-01-30 00:00	Garry Parker		
281	Other	Hangar	Work Complete	2020-01-27 08:37	Michele Renfro	18H needs to be cleaned customer move out.	\$ 0.00	0.0	2020-01-29 00:00	Garry Parker		
291	Lighting	Hangar	Work Complete	2020-02-04 09:26	Garry Parker	Hangar 18-A exterior light is not working: Repair or Replace/upgrade fixture.	\$ 0.00	0.0	2020-03-16 00:00	Jose Aviles		
296	Other	Hangar	Work Complete	2020-02-10 10:25	Michele Renfro	15B latch needs to be removed and replaced with new shorter latch to make it connect to the eyelet for locking.	\$ 0.00	1.0	2020-03-06 00:00	Jose Aviles		
297	Other	Hangar	Work Complete	2020-02-10 10:29	Michele Renfro	15B was cleaned but doors and floor needs to be pressure washed to remove pigeon matter on doors and floors.	\$ 0.00	3.0	2020-04-03 00:00	Jose Aviles		
298	Other	Hangar	Work Complete	2020-02-10 16:41	Michele Renfro	16A- Open screw holes on the door, left side panel in several locations, back wall at top. Photos attached.	\$ 0.00	2.0	2020-03-16 00:00	Jose Aviles		
299	Roof	Hangar	Work Complete	2020-02-10 16:43	Michele Renfro	16A - Roof leak on right side of hangar over car could not tell where it was coming from. Leak in middle of hangar at the roof near beam. Photo attached.	\$ 0.00	2.0	2020-03-16 00:00	Jose Aviles		

301	Lighting	Hangar	Work Complete	2020-02-10 16:46	Michele Renfro	2A - Back light in hangar is blown and fixture seems to be coming out of the ceiling. Customer stated the fixture is spinning and light bulb will not come out of the housing.	\$ 0.00	2.0	2020-03-10 00:00	Jose Aviles		
303	Pavements	Taxiway	Work Complete	2020-02-10 16:49	Michele Renfro	Between Hangar 15 & 6 water backing up into taxi lane due to water not being able to flow through grass and soil to make it to the drainage ditch. Photos attached.	\$ 0.00	0.0	2020-11-03 00:00	Daniel Thomas Sr.		
304	Facilities	Hangar	Work Complete	2020-02-10 16:51	Michele Renfro	6C Back of hangar angle iron rusted out with holes present. Photos attached	\$ 0.00	8.0	2020-05-28 00:00	Jose Aviles		
305	Door/Gate	Hangar	Work Complete	2020-02-10 16:56	Michele Renfro	6C - 2nd door gets stuck when opening hangar 1/2 way down	\$ 0.00	2.0	2020-05-28 00:00	Jose Aviles		
306	Roof	Hangar	Work Complete	2020-02-10 16:58	Michele Renfro	6C Front right side of hangar has new roof leaks. Photos attached.	\$ 0.00	2.0	2020-05-28 00:00	Jose Aviles		
307	Door/Gate	Hangar	Work Complete	2020-02-10 16:59	Michele Renfro	21B- Right door hanging up on other door @ top when open all the way. When trying to close it pulls both doors where it is hanging up on top making it hard to close the 1st door. Debbie would prefer to be present on Friday's when looking at the hangar.	\$ 0.00	8.0	2020-09-28 00:00	Jose Aviles		
311	Roof	Hangar	Work Complete	2020-02-12 11:39	Michele Renfro	4B - Roof is leaking in several locations. Photos attached	\$ 0.00	0.0	2020-03-09 00:00	Jose Aviles		
353	Roof	Hangar	Work Complete	2020-03-04 15:03	Michele Renfro	5F roof leaking over right wing of aircraft.	\$ 0.00	1.0	2020-03-06 00:00	Jose Aviles		
354	Roof	Hangar	Work Complete	2020-03-04 15:43	Garry Parker	Hangar 57 has multiple roof leaks that have worsened in a brief period of time. The RFP was published and a contract for Roof Overlay project was awarded to Thayer-Bray Construction.	\$ 50,000.00	0.0	2020-07-31 00:00	Garry Parker		
356	Door/Gate	Hangar	Work Complete	2020-03-06 08:12	Amber Clark	21-I Doors need to be sealed -when others crank up their plane all kinds of stuff is blown into the hangar, even with the doors closed	\$ 0.00	16.0	2020-09-08 00:00	Jose Aviles		
357	Other	Hangar	In Progress	2020-03-06 08:15	Amber Clark	16G Lip in the concrete at the entrance makes getting the aircraft in difficult- needs to be grinded down	\$ 0.00	0.0				
358	Door/Gate	Hangar	In Progress	2020-03-06 08:18	Amber Clark	16G-Doors do not seal	\$ 0.00	0.0				
359	Other	Hangar	In Progress	2020-03-06 08:22	Amber Clark	Hangar 16G- Standing water in hangar- Unsure as to the cause, please check when it has been raining	\$ 0.00	0.0				
380	Other	Hangar	Work Complete	2020-03-16 09:49	Garry Parker	Multiple leaks are present due to side walls being open and exposed as the the rubber seals have deteriorated on walls and doors facing the parking lot. Hangar 57 Install new rubber seals that are backordered when they arrive.	\$ 0.00	0.0	2021-02-26 00:00	Daniel Thomas Sr.		
392	Lighting	Hangar	Work Complete	2020-03-20 11:49	Jose Aviles	Hangar 2A: Maintenance recently replaced 2 light sockets and 2 3-way light switches. Light sources currently in the hangar is not efficient enough lighting up the hangar. Especially when working on their aircraft. Recommend installing an LED fixture to provide adequate lighting in the area. End of report.	\$ 0.00	12.0	2020-08-17 00:00	Jose Aviles		
401	Door/Gate	Hangar	Work Complete	2020-03-25 14:54	Garry Parker	Hangar 17A: Check the sheet metal placement at top of the door to ensure that it isn't preventing the door from closing. If so, adjust as necessary or remove and place Bird Gel Disc at the entry point	\$ 0.00	0.0	2020-03-25 00:00	Jose Aviles		
434	Other	Hangar	Work Complete	2020-04-02 11:42	Jose Aviles	18H-Need to seal an 2x2 inch hole that allowing water too enter the hangar, as well as seal multiple holes on the back side wall of the hangar and on the roof.	\$ 0.00	2.0	2020-04-02 00:00	Jose Aviles		
435	Other	Hangar	Work Complete	2020-04-02 11:52	Jose Aviles	21G-Random holes on back wall of hangar, hangar doors difficult moving.	\$ 0.00	2.0	2020-04-02 00:00	Jose Aviles		

436	Other	Hangar	Work Complete	2020-04-02 11:55	Jose Aviles	21A- Due too the ground/dirt exceeding past the floor level of the hanger's floor on the side of the wall. When raining would occur water would easily make its way inside the hanger. Maintenance simply dug away the ground/dirt away from the side walls to prevent easy water entry. End of report.	\$ 0.00	1.0	2020-04-02 00:00	Jose Aviles		
466	Lighting	Hangar	Work Complete	2020-04-20 10:59	Garry Parker	Hangar 19 has several lights out that need to be replaced. Point of contact Robert or Jack.	\$ 0.00	1.0	2020-04-21 00:00	Jose Aviles		
467	Other	Hangar	Work Complete	2020-04-21 08:18	Jose Aviles	Hanger 19 (CAS) interior light need to be replaced, roof leaking.	\$ 0.00	3.0	2020-04-21 00:00	Jose Aviles		
481	Lighting	Hangar	Work Complete	2020-04-28 09:54	Michele Renfro	15B tenant called and stated the light is still missing as well as the inside portion of the doors still have pigeon matter on them and could it please be pressure washed to remove prior dirt and debris.	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles		
482	Other	Hangar	Work Complete	2020-04-28 20:31	Michele Renfro	6A hangar needs to be cleaned for tenant move in on May 1st. Please check to make sure the light is working on the wooden side partitions are secured with nails and not rotten. or falling over.	\$ 0.00	4.0	2020-09-08 00:00	Jose Aviles		
483	Wildlife	Hangar	In Progress	2020-04-28 20:34	Michele Renfro	11 Bay 4 Skip Williams called and stated he has been seeing pigeons in his hangar right by the office door to the right.	\$ 0.00	0.0				
487	Roof	Hangar	Work Complete	2020-04-29 14:07	Garry Parker	Hangar 12: Multiple Holes in the roof and side panels . Technicians need to gain access to the hangar during rain. #1. Utilizing the lift, identify the holes at roof level and follow up with repair. #2. Pigeon mitigation and entry prevention: Expel pigeons and close points of entry. #3. Replace center door seals facing G.A. apron. Point of contact for hangar entry is tenant/representative Greg Russell: gwr@ldl.net	\$ 0.00	8.0	2020-06-08 00:00	Jose Aviles		
492	Facilities	Hangar	Work Complete	2020-05-04 09:38	Garry Parker	Hangar 7A, 7B, 4B all bays. Install chicken wire barrier at the gaps separating hangars (from wall to roof). Prevent birds from crossing from one bay to the next. Coordinate with Michele and Daniel.	\$ 0.00	0.0	2020-09-17 00:00	Jose Aviles		
495	Roof	Hangar	In Progress	2020-05-05 10:14	Michele Renfro	7A Customer states work order was completed and closed in January on roof leak but roof is still leaking on right side of hangar.	\$ 0.00	0.0				
499	Other	Hangar	In Progress	2020-05-05 10:51	Michele Renfro	7A Customer states that water is still coming in on back wall as well as seeping up through the floor on the back right side of hangar.	\$ 0.00	0.0				
500	Door/Gate	Hangar	In Progress	2020-05-06 12:14	Michele Renfro	3A Customer states left inner door is hard to push and open all the way	\$ 0.00	0.0				
503	Lighting	Hangar	Work Complete	2020-05-07 09:57	Michele Renfro	Jose, Please coordinate with Michele for hangar entry authorization from the tenant. 3A Customer states light is out in hangar	\$ 0.00	1.0	2020-06-16 00:00	Jose Aviles		
504	Plumbing	Hangar	Work Complete	2020-05-07 11:18	Garry Parker	Plumbing/pipe leak in the offices at Hangar 57. Point of contact is Richard Desportes.	\$ 0.00	5.0	2020-05-13 00:00	Jose Aviles		
511	Other	Hangar	In Progress	2020-05-11 09:24	Michele Renfro	5F Customer states when raining water pours in under the outside wall panel by the grass area of the hangar into the storage area that is connected to the hangar.	\$ 0.00	0.0				
512	Door/Gate	Hangar	In Progress	2020-05-11 13:57	Michele Renfro	7C pigeons getting through holes at top of door. Customer stated he had noticed bird matter on his plane	\$ 0.00	0.0				
513	Other	Hangar	In Progress	2020-05-11 14:33	Michele Renfro	4C outside gutter needs to be sealed at crack, photo attached	\$ 0.00	0.0				
515	Door/Gate	Hangar	Work Complete	2020-05-11 14:37	Michele Renfro	H13 Metal on door panel was caught on door frame and rip the metal away from the screws. Also welding iron on door and bottom frame to make door close.	\$ 0.00	18.0	2020-08-17 00:00	Jose Aviles		
516	Facilities	Hangar	Work Complete	2020-05-11 14:39	Michele Renfro	6A Original work order was completed and close but hangar was not completed. Hangar still needs to be cleaned for new tenant move in.	\$ 0.00	0.0	2020-08-11 00:00	Garry Parker		

517	Facilities	Hangar	Work Complete	2020-05-11 14:41	Michele Renfro	1F Customer has moved out. Please have entire hangar cleaned for new customer rental.	\$ 0.00	4.0	2020-06-24 00:00	Jose Aviles		
518	Facilities	Hangar	Work Complete	2020-05-11 14:43	Michele Renfro	7A Please see attached photos of back wall angle iron rusted as well as water under the painted floor surface. Needs to be sealed along back wall and side wall to prevent water from getting under painted floor. Photos also show corner post.	\$ 0.00	3.0	2020-05-27 00:00	Jose Aviles		
522	Electrical	Hangar	Work Complete	2020-05-14 13:01	Michele Renfro	5B Customer states switch to let the door up and down has been failing. Today when he came back in the door let down but the switch will not reengage to let the door back up.	\$ 0.00	0.0	2020-05-27 00:00	Jose Aviles		
542	Door/Gate	Hangar	Work Complete	2020-05-26 09:10	Michele Renfro	9F Customer stated that within the last couple of weeks the third door is extremely hard to open. Could you please check to see if something is jamming the rollers or the track.	\$ 0.00	2.0	2020-06-23 00:00	Jose Aviles		
546	Door/Gate	Hangar	Work Complete	2020-05-28 14:00	Jack Bartholet	Hangar 1B, door out of adjustment	\$ 0.00	8.0	2020-08-17 00:00	Jose Aviles		
547	Erosion	Hangar	Work Complete	2020-05-28 14:06	Garry Parker	Hangar 19 NW side has an opening in the asphalt that causes debris and fod to wash out on to the taxiway.	\$ 0.00	0.0	2020-05-29 00:00	Daniel Thomas Sr.		
564	Hazard	Hangar	Work Complete	2020-06-09 08:40	Jack Bartholet	Hangar 1B - upper hangar wall is falling in	\$ 0.00	3.0	2020-08-17 00:00	Jose Aviles		
568	Other	Landscaping	Work Complete	2020-06-11 14:50	Michele Renfro	4A Dirt mound at end of hangar needs to be shoveled down to keep ants from getting into hangar and building a mound.	\$ 0.00	0.0	2020-06-11 00:00	Daniel Thomas Sr.		
569	Other	Hangar	Work Complete	2020-06-11 14:51	Michele Renfro	1B - 12 ft Panel running left to right on back left side of wall is falling away from the ceiling. Hazard could fall on plane.	\$ 0.00	0.0	2020-08-10 00:00	Garry Parker		
570	Door/Gate	Hangar	In Progress	2020-06-11 14:51	Michele Renfro	15 Hangar- All door panels with rollers on all bays needs screws to be put in to keep the panel that holds on the rollers from bowing. 3/4 of the screws that hold the door panel with rollers that holds the door to the hangar is missing. Extreme concern with a heavy wind the door may fall if screws not replaced.	\$ 0.00	0.0				
571	Door/Gate	Hangar	In Progress	2020-06-11 14:52	Michele Renfro	14 Hangar- All door panels with rollers on all bays needs screws to be put in to keep the panel that holds on the rollers from bowing. 3/4 of the screws that hold the door panel with rollers that holds the door to the hangar is missing. Extreme concern with a heavy wind the door may fall if screws not replaced.	\$ 0.00	0.0				
573	Door/Gate	Crash Station	In Progress	2020-06-11 14:54	Raymond Keeler	Bay Door 3 is not closing properly and the close must be pressed until door is completely closed.	\$ 0.00	0.0				
587	Lighting	Hangar	Work Complete	2020-06-16 16:18	Jose Aviles	3A interior light out need to be replaced	\$ 0.00	1.0	2020-06-16 00:00	Jose Aviles		
588	Lighting	Hangar	Work Complete	2020-06-18 15:38	Garry Parker	Hangar 19 - one light out. Please contact Robert Boehlein	\$ 0.00	0.0	2020-08-11 00:00	Garry Parker		
601	Other	Hangar	Work Complete	2020-06-24 13:19	Michele Renfro	5D end all the way down hangar needs to be caulked to help the water from going under the metal and entering the hangar.	\$ 0.00	2.0	2020-06-24 00:00	Jose Aviles		
602	Door/Gate	Hangar	Work Complete	2020-06-24 13:20	Michele Renfro	6B Customer stated 3rd hangar door hanging up on screws and 2nd door. Hard to open with one person	\$ 0.00	0.0	2020-09-22 00:00	Jose Aviles		
603	Other	Hangar	Work Complete	2020-06-24 13:20	Michele Renfro	15F Hangar needs to be cleaned on floor and doors from pigeon matter. Michele must call tenant to move aircraft before cleaning.	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles		
604	Other	Hangar	Work Complete	2020-06-24 13:21	Michele Renfro	15C Hangar needs to be cleaned on floor and doors from pigeon matter	\$ 0.00	4.0	2020-06-24 00:00	Jose Aviles		
605	Other	Hangar	Work Complete	2020-06-24 13:21	Michele Renfro	15A Hangar needs to be cleaned from pigeon matter on floor and doors	\$ 0.00	4.0	2020-06-24 00:00	Jose Aviles		

630	Lighting	Hangar	Work Complete	2020-07-11 19:04	Daniel Thomas Sr.	WORK REQUEST # 223 BY ANDREW RAMBO SERRANO ON JUNE 30, 2020 AT 20:36. Outside light above hangar 5-C is filling with water. The lower set of LEDs in the light assembly has already shorted out and no longer works. The area is now very dark at night.	\$ 0.00	0.0	2020-07-20 00:00	Daniel Thomas Sr.		
636	Roof	Hangar	In Progress	2020-07-14 10:15	Michele Renfroe	2C - Customer states that the 2 front roof seams are leaking on the wings of his aircraft. Could we please seal the seams?	\$ 0.00	0.0				
639	HVAC	Crash Station	Work Complete	2020-07-14 16:31	Richard Baran	HP-3 does not seem to be working. Air conditioning for dorm rooms 118-124 is not working.	\$ 0.00	2.0	2020-08-17 00:00	Jose Aviles		
646	Lighting	Hangar	Work Complete	2020-07-16 15:31	Garry Parker	Hangar # 19 - Replace inoperative overhead lights with LED upgrades.	\$ 0.00	0.0	2020-08-05 00:00	Garry Parker		
647	Roof	Hangar	In Progress	2020-07-16 15:35	Garry Parker	Hangar# 19 - Multiple holes in the roof causing leaks. Assess and repair. If temporary and fast repair is possible, annotate this on the work order and leave the work order open until a permanent repair is complete.	\$ 0.00	0.0				
660	Roof	Hangar	In Progress	2020-07-27 14:33	Austin Edwards	17-A Leaking hangar. See pictures attached.	\$ 0.00	0.0				
663	Door/Gate	Hangar	In Progress	2020-07-31 08:33	Michele Renfroe	11 Bay 3 - Customer states that the doors are still extremely hard to open and close especially with one person. This is the feedback they received from a survey they sent out to all the RCAC members. They would like to see the motors could be put on the doors to help with opening and closing them.	\$ 0.00	0.0				
664	Door/Gate	Hangar	Work Complete	2020-07-31 08:34	Robert Boehnlein	Hangar 19 doors are becoming almost impossible to open without machinery.	\$ 0.00	0.0	2020-08-17 00:00	Garry Parker		
684	Door/Gate	Hangar	Work Complete	2020-08-16 21:01	David E. Hammonds (Rick)	Hangar 3F - door is off track	\$ 0.00	0.0	2020-08-17 00:00	Garry Parker		
688	Other	Hangar	Work Complete	2020-08-19 09:05	Michele Renfroe	3C - Customer moved out and needs to be cleaned for new customer move in. Please empty final contents, clean floors, back of doors and tracks.	\$ 0.00	3.0	2020-09-08 00:00	Jose Aviles		
689	Other	Hangar	Work Complete	2020-08-20 12:25	Michele Renfroe	11 Bay 6 needs to be cleaned for tenant move out	\$ 0.00	4.0	2020-09-08 00:00	Jose Aviles		
690	Door/Gate	Hangar	In Progress	2020-08-20 12:26	Michele Renfroe	10C - customer states doors are jumping track and have a gap each time he opens the hangar.	\$ 0.00	0.0				
710	Lighting	Hangar	Work Complete	2020-09-17 11:19	Jose Aviles	16D exterior light affecting pilots field of vision. Adjusted light. If any issues still occur. It will be addressed.	\$ 0.00	2.0	2020-09-17 00:00	Jose Aviles		
713	Other	Hangar	Work Complete	2020-09-17 11:35	Jose Aviles	14A back wall angle iron is rusted out allowing bugs and water to enter the wall.	\$ 0.00	4.0	2020-09-17 00:00	Jose Aviles		
714	Wildlife	Hangar	Work Complete	2020-09-21 16:23	Jose Aviles	Hangar 21J door gap needs to be closed for birds.	\$ 0.00	3.0	2020-09-21 00:00	Jose Aviles		
715	Wildlife	Hangar	Work Complete	2020-09-21 16:25	Jose Aviles	Hangar 21G door gaps need to be enclosed due to birds.	\$ 0.00	3.0	2020-09-21 00:00	Jose Aviles		
716	Other	Hangar	Work Complete	2020-09-21 16:28	Jose Aviles	Hangar 17A backwall seeping in water when raining.	\$ 0.00	2.0	2020-09-21 00:00	Jose Aviles		
717	Wildlife	Hangar	Work Complete	2020-09-21 16:30	Jose Aviles	Hangar 12 has bird dropping all over floor need to clean.	\$ 0.00	4.0	2020-09-21 00:00	Jose Aviles		
718	Electrical	Hangar	Work Complete	2020-09-21 16:32	Jose Aviles	Hangar 21J electrical outlet needs to be replaced, as well as the light switch.	\$ 0.00	2.0	2020-09-21 00:00	Jose Aviles		
719	Door/Gate	Hangar	Work Complete	2020-09-22 16:23	Jose Aviles	Hangar 6B 3rd inner door is sticking. Hard to move.	\$ 0.00	1.0	2020-09-22 00:00	Jose Aviles		
725	Erosion	Hangar	In Progress	2020-09-25 08:58	Michele Renfroe	H57 - Customer sent pictures showing that during the last hard rain he had mud come through the walls from the outside where the dirt is piled higher than the hangar in side the fence.	\$ 0.00	0.0				

728	Door/Gate	Hangar	Work Complete	2020-10-04 21:44	Michele Renfro	H20 - Travis w/ FWC called and stated that when closing the door on 10/04/20 one of the door straps broke. Pictures are attached.	\$ 0.00	6.0	2020-10-09 00:00	Jose Aviles		
740	Hazard	Hangar	In Progress	2020-10-13 15:37	Michele Renfro	7C - Customer states that water comes in back of hangar when it rains really hard. Need to check for the angle iron on back side of interior wall.	\$ 0.00	0.0				
741	HVAC	Hangar	In Progress	2020-10-13 15:37	Michele Renfro	6D - Customer states air-conditioner is not working in the office area.	\$ 0.00	0.0				
742	HVAC	Hangar	Work Complete	2020-10-13 15:38	Michele Renfro	H57 - Heaters inside hangar does not work. Panels were taken down and never replaced or fixed. Picture is attached.	\$ 0.00	0.0	2021-02-26 00:00	Daniel Thomas Sr.		
743	Door/Gate	Hangar	Work Complete	2020-10-13 15:38	Michele Renfro	H57 - Door seal on bottom of parking lot side of door not complete. Seal is hanging and screws are missing from panel. Pictures are attached.	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles		
744	Door/Gate	Hangar	In Progress	2020-10-13 15:38	Michele Renfro	H57-Ramp side door is rubbing on gas line running down side of building. Hazard and pictures are attached.	\$ 0.00	0.0				
745	Door/Gate	Hangar	In Progress	2020-10-13 15:39	Michele Renfro	H57- Door gaps and seals need to be replaced on both sides ramp and parking lot side. Pictures are attached	\$ 0.00	0.0				
746	Door/Gate	Hangar	In Progress	2020-10-13 15:39	Michele Renfro	H57- Rollers on all doors need to be greased and possibly adjusted to open smoother. Doors are hard to open and get stuck when trying to open. Pictures are attached	\$ 0.00	0.0				
747	Lighting	Hangar	Work Complete	2020-10-13 15:40	Michele Renfro	H57- Light at end of hangar on ramp side of 57 was just hanging from where the new roof was put on and in the last big wind it blew off. Housing and light bulb needs to be replaced. Pictures attached.	\$ 0.00	0.0	2021-02-26 00:00	Daniel Thomas Sr.		
758	Lock	Hangar	In Progress	2020-10-21 17:56	Michele Renfro	1B - Customer states that when the doors were worked on it has caused an issue with being able to lock the door. The latch does not line up with each other so it prevents him from locking his hangar doors. Picture attached.	\$ 0.00	0.0				
759	Wildlife	Hangar	Work Complete	2020-10-21 17:56	Michele Renfro	H57 Office - Customer stated that he is still seeing presence of mice/rats in the office area at hangar 57.	\$ 0.00	0.0	2021-03-10 00:00	Daniel Thomas Sr.		
760	Wildlife	Hangar	In Progress	2020-10-21 17:57	Michele Renfro	6E - Customer stated he saw fecal matter from pigeons but no birds present.	\$ 0.00	0.0				
761	Holes	Hangar	In Progress	2020-10-21 17:58	Michele Renfro	7C - Angle iron is rusted at back wall of hangar allowing water to come into the hangar. Some parts are rusted out and needs to be replaced. Side walls also need to be caulked.	\$ 0.00	0.0				
783	Wildlife	Hangar	In Progress	2020-10-28 08:34	Michele Renfro	12 - Customer called and stated that an owl had gotten in the hangar as well as pigeons. Pictures are attached.	\$ 0.00	0.0				
784	Roof	Hangar	In Progress	2020-10-28 08:35	Michele Renfro	16A - Customer states that water is leaking from the roof as well as coming in under the door. Also states that the peg board is starting to fall off the wall due to moisture. Pictures are attached.	\$ 0.00	0.0				
785	Holes	Hangar	In Progress	2020-10-30 08:13	Michele Renfro	16C - Holes in the ceiling all the way down one panel, on doors and water comes in on each side of hangar walls.	\$ 0.00	0.0				
786	Other	Hangar	In Progress	2020-10-30 08:14	Michele Renfro	17A - Customer states when heavy rain water is leaking center back section of hangar at floor level. Picture attached	\$ 0.00	0.0				
788	Door/Gate	Hangar	In Progress	2020-10-31 07:39	Daniel Thomas Sr.	5-E. this is RDs hangar. The clamshell-style hangar door controller is not working correctly, you flip the switch on the direction of door travel and then you will have to hold in the electrical contactor to power up the door. If you don't let go of the contactor in enough time, you will break the door cables because the doorstop safety switches don't work. a Correct working clamshell-style hangar door just uses the switch only and without holding it to make it work or stop.	\$ 0.00	0.0				



790	Other	Hangar	In Progress	2020-11-03 14:28	Jose Aviles	1F- Hangar door slides off door tracks.	\$ 0.00	0.0				
791	Other	Hangar	In Progress	2020-11-03 14:31	Jose Aviles	1D- Far right hangar door jumps off track when heavy winds are occurring.	\$ 0.00	0.0				
792	Electrical	Hangar	In Progress	2020-11-03 14:35	Jose Aviles	2C- Hangar interior electrical needs to be removed and install new wire, conduit, outlets, light switches and interior lights.	\$ 0.00	0.0				
793	Other	Hangar	In Progress	2020-11-03 14:39	Jose Aviles	4D- Gutter needs to be adjusted and sealed in some areas	\$ 0.00	0.0				
794	Other	Hangar	In Progress	2020-11-03 14:40	Jose Aviles	4E- Gutter needs to be adjusted and sealed in some areas.	\$ 0.00	0.0				
796	Door/Gate	Hangar	In Progress	2020-11-04 05:03	Michele Renfro	16H - Door seals need to be replaced	\$ 0.00	0.0				
797	Door/Gate	Hangar	In Progress	2020-11-04 05:04	Michele Renfro	16G - Door seals need to be replaced	\$ 0.00	0.0				
798	Door/Gate	Hangar	In Progress	2020-11-04 05:04	Michele Renfro	16F - Door seals need to be replaced	\$ 0.00	0.0				
799	Door/Gate	Hangar	In Progress	2020-11-04 05:05	Michele Renfro	16E - Door seals need to be replaced	\$ 0.00	0.0				
800	Door/Gate	Hangar	In Progress	2020-11-04 05:05	Michele Renfro	16D - Door seals need to be replaced	\$ 0.00	0.0				
801	Door/Gate	Hangar	In Progress	2020-11-04 05:06	Michele Renfro	16C - Door seals need to be replaced	\$ 0.00	0.0				
802	Door/Gate	Hangar	In Progress	2020-11-04 05:06	Michele Renfro	16B - Door seals need to be replaced	\$ 0.00	0.0				
803	Door/Gate	Hangar	In Progress	2020-11-04 05:07	Michele Renfro	16A - Door seals need to be replaced	\$ 0.00	0.0				
804	Door/Gate	Hangar	In Progress	2020-11-04 05:07	Michele Renfro	17J - Door seals need to be replaced	\$ 0.00	0.0				
805	Door/Gate	Hangar	In Progress	2020-11-04 05:08	Michele Renfro	17I - Door seals need to be replaced	\$ 0.00	0.0				
806	Door/Gate	Hangar	In Progress	2020-11-04 05:08	Michele Renfro	17H - Door seals need to be replaced	\$ 0.00	0.0				
807	Door/Gate	Hangar	In Progress	2020-11-04 05:09	Michele Renfro	17G - Door seals need to be replaced	\$ 0.00	0.0				
808	Door/Gate	Hangar	In Progress	2020-11-04 05:09	Michele Renfro	17F - Door seals need to be replaced	\$ 0.00	0.0				
809	Door/Gate	Hangar	In Progress	2020-11-04 05:10	Michele Renfro	17E - Door seals need to be replaced	\$ 0.00	0.0				
810	Door/Gate	Hangar	In Progress	2020-11-04 06:37	Michele Renfro	17D - Door seals need to be replaced	\$ 0.00	0.0				
811	Door/Gate	Hangar	In Progress	2020-11-04 06:38	Michele Renfro	17C - Door seals need to be replaced	\$ 0.00	0.0				
812	Door/Gate	Hangar	In Progress	2020-11-04 06:38	Michele Renfro	17B - Door seals need to be replaced	\$ 0.00	0.0				
813	Door/Gate	Hangar	In Progress	2020-11-04 06:38	Michele Renfro	17A - Door seals need to be replaced	\$ 0.00	0.0				
814	Door/Gate	Hangar	In Progress	2020-11-04 06:39	Michele Renfro	18J - Door seals need to be replaced	\$ 0.00	0.0				
815	Door/Gate	Hangar	In Progress	2020-11-04 06:39	Michele Renfro	18I - Door seals need to be replaced	\$ 0.00	0.0				
816	Door/Gate	Hangar	In Progress	2020-11-04 06:39	Michele Renfro	18H - Door seals need to be replaced	\$ 0.00	0.0				
817	Door/Gate	Hangar	In Progress	2020-11-04 06:40	Michele Renfro	18G - Door seals need to be replaced	\$ 0.00	0.0				
818	Door/Gate	Hangar	In Progress	2020-11-04 06:40	Michele Renfro	18F - Door seals need to be replaced	\$ 0.00	0.0				
819	Door/Gate	Hangar	In Progress	2020-11-04 06:40	Michele Renfro	18E - Door seals need to be replaced	\$ 0.00	0.0				
820	Door/Gate	Hangar	In Progress	2020-11-04 06:41	Michele Renfro	18D - Door seals need to be replaced	\$ 0.00	0.0				
821	Door/Gate	Hangar	In Progress	2020-11-04 06:41	Michele Renfro	18C - Door seals need to be replaced	\$ 0.00	0.0				
822	Door/Gate	Hangar	In Progress	2020-11-04 06:41	Michele Renfro	18B - Door seals need to be replaced	\$ 0.00	0.0				

823	Door/Gate	Hangar	In Progress	2020-11-04 06:42	Michele Renfro	18A - Door seals need to be replaced	\$ 0.00	0.0				
824	Door/Gate	Hangar	In Progress	2020-11-04 06:42	Michele Renfro	21J - Door seals need to be replaced	\$ 0.00	0.0				
825	Door/Gate	Hangar	In Progress	2020-11-04 06:42	Michele Renfro	21I - Door seals need to be replaced	\$ 0.00	0.0				
826	Door/Gate	Hangar	In Progress	2020-11-04 06:43	Michele Renfro	21H - Door seals need to be replaced	\$ 0.00	0.0				
827	Door/Gate	Hangar	In Progress	2020-11-04 06:43	Michele Renfro	21G - Door seals need to be replaced	\$ 0.00	0.0				
828	Door/Gate	Hangar	In Progress	2020-11-04 06:43	Michele Renfro	21F - Door seals need to be replaced	\$ 0.00	0.0				
829	Door/Gate	Hangar	In Progress	2020-11-04 06:48	Michele Renfro	21E - Door seals need to be replaced	\$ 0.00	0.0				
830	Door/Gate	Hangar	In Progress	2020-11-04 06:48	Michele Renfro	21D - Door seals need to be replaced	\$ 0.00	0.0				
831	Door/Gate	Hangar	In Progress	2020-11-04 06:49	Michele Renfro	21C - Door seals need to be replaced	\$ 0.00	0.0				
832	Door/Gate	Hangar	In Progress	2020-11-04 06:49	Michele Renfro	21B - Door seals need to be replaced	\$ 0.00	0.0				
833	Door/Gate	Hangar	In Progress	2020-11-04 06:49	Michele Renfro	21A - Door seals need to be replaced	\$ 0.00	0.0				
834	Door/Gate	Hangar	In Progress	2020-11-04 06:50	Michele Renfro	14F - Door seals need to be replaced	\$ 0.00	0.0				
835	Door/Gate	Hangar	In Progress	2020-11-04 06:50	Michele Renfro	14E - Door seals need to be replaced	\$ 0.00	0.0				
836	Door/Gate	Hangar	In Progress	2020-11-04 06:50	Michele Renfro	14D - Door seals need to be replaced	\$ 0.00	0.0				
837	Door/Gate	Hangar	In Progress	2020-11-04 06:50	Michele Renfro	14C - Door seals need to be replaced	\$ 0.00	0.0				
838	Door/Gate	Hangar	In Progress	2020-11-04 06:51	Michele Renfro	14B - Door seals need to be replaced	\$ 0.00	0.0				
839	Door/Gate	Hangar	In Progress	2020-11-04 06:51	Michele Renfro	14A - Door seals need to be replaced	\$ 0.00	0.0				
840	Door/Gate	Hangar	In Progress	2020-11-04 06:51	Michele Renfro	15F - Door seals need to be replaced	\$ 0.00	0.0				
841	Door/Gate	Hangar	In Progress	2020-11-04 06:51	Michele Renfro	15E - Door seals need to be replaced	\$ 0.00	0.0				
842	Door/Gate	Hangar	In Progress	2020-11-04 06:52	Michele Renfro	15D - Door seals need to be replaced	\$ 0.00	0.0				
843	Door/Gate	Hangar	In Progress	2020-11-04 06:52	Michele Renfro	15C - Door seals need to be replaced	\$ 0.00	0.0				
844	Door/Gate	Hangar	In Progress	2020-11-04 06:52	Michele Renfro	15B - Door seals need to be replaced	\$ 0.00	0.0				
845	Door/Gate	Hangar	In Progress	2020-11-04 06:53	Michele Renfro	15A - Door seals need to be replaced	\$ 0.00	0.0				
846	Door/Gate	Hangar	In Progress	2020-11-04 06:53	Michele Renfro	5F - Door seals need to be replaced	\$ 0.00	0.0				
847	Door/Gate	Hangar	In Progress	2020-11-04 06:53	Michele Renfro	5E - Door seals need to be replaced	\$ 0.00	0.0				
848	Door/Gate	Hangar	In Progress	2020-11-04 06:53	Michele Renfro	5D - Door seals need to be replaced	\$ 0.00	0.0				
849	Door/Gate	Hangar	In Progress	2020-11-04 06:54	Michele Renfro	5C - Door seals need to be replaced	\$ 0.00	0.0				
850	Door/Gate	Hangar	In Progress	2020-11-04 06:54	Michele Renfro	5B - Door seals need to be replaced	\$ 0.00	0.0				
851	Door/Gate	Hangar	In Progress	2020-11-04 06:54	Michele Renfro	5A - Door seals need to be replaced	\$ 0.00	0.0				
852	Door/Gate	Hangar	In Progress	2020-11-04 06:54	Michele Renfro	3C - Door seals need to be replaced	\$ 0.00	0.0				
853	Door/Gate	Hangar	In Progress	2020-11-04 06:55	Michele Renfro	2C - Door seals need to be replaced under the front of the door to keep rain from blowing in under the doors	\$ 0.00	0.0				
863	Door/Gate	Hangar	In Progress	2020-11-17 14:47	Michele Renfro	H13 door tracks on both sides where doors open on and roll need to be welded and door stops need to be welded on the doors, weld stop needs to be added on FWC side where phone lines go from office to ground so doors can't be opened too far to clip the phone lines.	\$ 0.00	0.0				

866	Lighting	Hangar	In Progress	2020-11-19 08:28	Marion Anderson	13 . Hangar 13 Light is out.	\$ 0.00	0.0			
867	Lighting	Hangar	In Progress	2020-11-19 08:29	Marion Anderson	18-G .The light above 18G is out.	\$ 0.00	0.0			
868	Lighting	Hangar	In Progress	2020-11-19 08:29	Marion Anderson	18-B .The light above 18-B is out.	\$ 0.00	0.0			
869	Lighting	Hangar	In Progress	2020-11-19 08:30	Marion Anderson	5-C .The light above 5C is out.	\$ 0.00	0.0			
870	Door/Gate	Hangar	In Progress	2020-11-19 12:45	Michele Renfro	15B - Customer states that he is having issues with pigeons accessing his hangar through the doors.	\$ 0.00	0.0			
871	Wildlife	Hangar	In Progress	2020-11-19 12:46	Michele Renfro	15B - Customer states that he is having issues with rats building nest inside his aircraft. Thinks the trash at the ends of the hangars is keeping them around the building.	\$ 0.00	0.0			
879	Other	Hangar	In Progress	2020-12-04 14:10	Michele Renfro	3C - Holes on left side of panel wall	\$ 0.00	0.0			
880	Door/Gate	Hangar	In Progress	2020-12-04 14:11	Michele Renfro	3C - Door seals need to be replaced, worn.	\$ 0.00	0.0			
881	Lighting	Hangar	In Progress	2020-12-04 14:11	Michele Renfro	3C - electrical fixtures need to be rewired. Has extra fixtures installed but are being ran by extension cords.	\$ 0.00	0.0			
885	Door/Gate	Hangar	Work Complete	2020-12-09 01:51	Michele Renfro	5A - Walk through door is sticking and hard to open/shut. FBO has key to open	\$ 0.00	0.0	2021-03-25 00:00	Daniel Thomas Sr.	
898	Holes	Hangar	In Progress	2020-12-21 16:51	Michele Renfro	16C - roof hole still present on panel to right when looking into the hangar from the ramp area.	\$ 0.00	0.0			
899	Wildlife	Hangar	Work Complete	2020-12-21 16:51	Michele Renfro	15B - Customer sent photos of birds on tracks, pigeon matter on doors and floors, nest on tracks	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles	
900	Other	Hangar	Work Complete	2020-12-21 16:55	Michele Renfro	16B - floors need to be cleaned and pressure washed to remove painted material coming up off the floor. Tenant moved out so complete cleaning needs to be done	\$ 0.00	0.0	2021-03-18 00:00	Daniel Thomas Sr.	
901	Other	Hangar	In Progress	2020-12-21 16:56	Michele Renfro	16C - Walls need to be painted to cover the red and blue paint on walls and around where the walls meet the floor as well as by the light fixture.	\$ 0.00	0.0			
902	Hazard	Hangar	Work Complete	2020-12-21 20:14	Michele Renfro	15C - clean floor and put temporary fix to doors for pigeon issue.	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles	
903	Lighting	Hangar	Work Complete	2020-12-21 20:15	Michele Renfro	H13 - ballast need to be changed in several of the lights in the office for Airventures in H13.	\$ 0.00	0.0	2021-03-26 00:00	Daniel Thomas Sr.	
904	Wildlife	Hangar	Work Complete	2020-12-21 20:15	Michele Renfro	15F - hangar floor needs to be cleaned and temporary fix put in place to keep birds out until permanent fixture can be put in place.	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles	
916	Door/Gate	Hangar	Work Complete	2020-12-22 18:00	Michele Renfro	1C - Doors are pushed to wrong side. Need to unlock and put doors back on the correct side so they can open.	\$ 0.00	0.0	2020-12-23 00:00	Daniel Thomas Sr.	
920	Lighting	Hangar	In Progress	2020-12-27 12:26	Daniel Thomas Sr.	5-C Hangar -The floodlight above hangar 5C that is supposed to illuminate the ramp between hangars 4 & 5 was completely inoperative last night (December 26th).	\$ 0.00	0.0			
921	Electrical	Hangar	Work Complete	2020-12-27 12:30	Daniel Thomas Sr.	4-D Hangar -The electrical outlet in hangar 4D does not work / does not seem to have power. All three circuit breakers in the outside panel on hangar 4 were closed, but all of those are relatively high amp breakers (60 A?) each. I assume there must be a sub-panel inside one of the hangars.	\$ 0.00	0.0	2021-03-09 00:00	Daniel Thomas Sr.	
938	Door/Gate	Crash Station	In Progress	2020-12-31 08:23	Andre Parker	Bay 3 door will not open. It appears that the clutch will not engage the door opening.	\$ 0.00	0.0			
939	Hazard	Hangar	Work Complete	2020-12-31 15:11	Daniel Thomas Sr.	Hangar 57 aircraft hanger bay needs emergency heat. the two ceiling-mounted heaters are not working and Holboork heating and a/c Co. are waiting for parts to come in to fix the two heaters. 12/23/2020	\$ 0.00	0.0	2020-12-31 00:00	Daniel Thomas Sr.	
940	Other	Hangar	Work Complete	2020-12-31 15:59	Daniel Thomas Sr.	Hanger 57 does not have any working smoke or co alarm detectors in the office or bay areas.	\$ 0.00	0.0	2020-12-31 00:00	Daniel Thomas Sr.	

946	Roof	Hangar	In Progress	2021-01-05 11:55	Michele Renfro	15C - Customer stated that roof is leaking and has gotten worse over the aircraft.	\$ 0.00	0.0			
947	Door/Gate	Hangar	Work Complete	2021-01-05 11:56	Michele Renfro	7A All three doors are stuck open, as well as hard to open 1st door all the time.	\$ 0.00	0.0	2021-01-05 00:00	Daniel Thomas Sr.	
948	Door/Gate	Hangar	In Progress	2021-01-05 11:56	Michele Renfro	7A Hangar doors need to be greased and adjusted so all 3 doors will be easier to open	\$ 0.00	0.0			
949	Holes	Hangar	In Progress	2021-01-05 12:18	Michele Renfro	17A - Customers sent photos which shows leaks in the hangar. Leaking at the floor level around the backside of the hangar wall. Leaking under the doors when the rain blows. Hole over airplane in roof area causing leaks. All files are attached that customer sent to me on 01/01/21.	\$ 0.00	0.0			
954	Lighting	Hangar	Work Complete	2021-01-13 14:21	Michele Renfro	6E - Hangar light is out. Also please check right hand side of wall. it looks light it is coming down causing a gap entrance from the other bays in the hangar.	\$ 0.00	0.0	2021-03-23 00:00	Daniel Thomas Sr.	
960	Lighting	Hangar	In Progress	2021-01-21 13:53	Michele Renfro	3F - light needs to be replaced it is super dim and hard to put away aircraft at night	\$ 0.00	0.0			
962	Lighting	Hangar	Work Complete	2021-01-22 14:37	Michele Renfro	H11 Bay 1 - Customer called and stated the lights are out in his hangar as well as the door being off track.	\$ 0.00	3.0	2021-01-29 00:00	Jose Aviles	
968	Door/Gate	Hangar	In Progress	2021-02-02 17:07	Michele Renfro	7A - Customer states the 1st door is still having issues opening seems to be hanging up maybe on the 2nd door.	\$ 0.00	0.0			
969	Lock	Hangar	Work Complete	2021-02-02 17:07	Michele Renfro	5H - door handle needs to be replaced with outdoor handle	\$ 0.00	0.0	2021-03-19 00:00	Daniel Thomas Sr.	
970	Lock	Hangar	Work Complete	2021-02-02 17:08	Michele Renfro	5G - door handle needs to be replaced with outdoor handle	\$ 0.00	0.0	2021-04-08 00:00	Daniel Thomas Sr.	
971	Lock	Hangar	Work Complete	2021-02-02 17:08	Michele Renfro	5F - door handle needs to be replaced with outdoor handle	\$ 0.00	0.0	2021-03-25 00:00	Daniel Thomas Sr.	
972	Lock	Hangar	Work Complete	2021-02-02 17:09	Michele Renfro	5E - door handle needs to be replaced with outdoor handle	\$ 0.00	0.0	2021-03-24 00:00	Daniel Thomas Sr.	
973	Lock	Hangar	Work Complete	2021-02-02 17:09	Michele Renfro	5D - door handle needs to be replaced with outdoor handle	\$ 0.00	0.0	2021-03-19 00:00	Daniel Thomas Sr.	
974	Lock	Hangar	Work Complete	2021-02-02 17:10	Michele Renfro	5C - door handle needs to be replaced with outdoor handle	\$ 0.00	0.0	2021-03-19 00:00	Daniel Thomas Sr.	
975	Lock	Hangar	Work Complete	2021-02-02 17:10	Michele Renfro	5B - door handle needs to be replaced with outdoor handle	\$ 0.00	0.0	2021-03-18 00:00	Daniel Thomas Sr.	
976	Lock	Hangar	Work Complete	2021-02-02 17:11	Michele Renfro	5A - door handle needs to be replaced with outdoor handle also door is sticking and hard to open	\$ 0.00	0.0	2021-03-18 00:00	Daniel Thomas Sr.	
990	Other	Hangar	Work Complete	2021-02-12 12:27	Michele Renfro	17I - Customer has moved out of hangar and needs to be checked for lighting and cleaning. Combo is 2586	\$ 0.00	0.0	2021-02-17 00:00	Daniel Thomas Sr.	
1006	HVAC	Hangar	Work Complete	2021-02-19 17:00	Daniel Thomas Sr.	HG-57 The two hangar bay heaters need to be replaced. This issue has been ongoing in trying to repair these heaters.	\$ 0.00	0.0	2021-02-19 00:00	Daniel Thomas Sr.	
1022	Wildlife	Airside	In Progress	2021-02-23 08:23	Daniel Thomas Sr.	15-B hangar, birds are still getting in. recheck door seals and block off all access inside of this hangar where birds are getting into the hangar.	\$ 0.00	0.0			
1023	Door/Gate	Hangar	Work Complete	2021-02-25 16:42	Ernie Kelly	Hangar 11, Bay 3 doors hang up when opening. The middle door drags the ground and makes it difficult if not impossible to continue opening or closing the doors if only one person is trying to move the doors. It is so difficult, one of the members of River City Aero Club (Richard Foucher) injured himself trying to open the doors on 2/20/21.	\$ 0.00	0.0	2021-02-26 00:00	Daniel Thomas Sr.	

1024	Door/Gate	Hangar	In Progress	2021-02-25 16:43	Michele Renfro	1E - Door needs to be rewelded and sheet metal fixed where the storm blew it off the track and bent the frame. MX has worked on this door already several times but not completed. Customer is asking how much longer it will be before they can return to their hangar.	\$ 0.00	0.0			
1025	Roof	Hangar	In Progress	2021-02-25 16:45	Michele Renfro	8D - Vacate hangar needs to have roof leak located and repaired. Leak is on left side of hangar at the T portion of the beam.	\$ 0.00	0.0			
1026	FOD	Foxtrot GA Ramp Area	Work Complete	2021-02-25 16:50	Michele Renfro	21H - Customer called and stated there is a lot of loose gravel starting at the hangar going out over the pavement to the grass area of hangar 21 taxiway side. Ask if we could run the sweeper truck over to pick up loose items.	\$ 0.00	0.0	2021-02-26 00:00	Daniel Thomas Sr.	
1031	Electrical	Hangar	Work Complete	2021-03-01 10:07	Amber Clark	16G needs new light line tech could not see to put the aircraft away	\$ 0.00	0.0	2021-03-02 00:00	Daniel Thomas Sr.	
1032	Electrical	Hangar	Work Complete	2021-03-02 17:34	Darryl Graham	Hangar 13 wall outlet in need of repair.	\$ 0.00	0.0	2021-03-17 00:00	Daniel Thomas Sr.	
1033	Other	Hangar	Work Complete	2021-03-02 17:34	Michele Renfro	6E - right hand side of wall is open to hangar. please check wall and nail back up if needed.	\$ 0.00	0.0	2021-03-04 00:00	Daniel Thomas Sr.	
1034	Electrical	Hangar	Work Complete	2021-03-02 17:35	Michele Renfro	6 - Entire hangar is out of power	\$ 0.00	0.0	2021-03-04 00:00	Daniel Thomas Sr.	
1035	Electrical	Hangar	Work Complete	2021-03-02 17:35	Michele Renfro	7 - Entire hangar is out of power.	\$ 0.00	0.0	2021-03-03 00:00	Daniel Thomas Sr.	
1046	Door/Gate	Hangar	In Progress	2021-03-04 13:04	Daniel Thomas Sr.	57-HG Landside door seals need to be trimmed up. they are now dragging the concrete making it hard to open the door.	\$ 0.00	0.0			
1048	Door/Gate	Hangar	In Progress	2021-03-05 13:19	Michele Renfro	21I - Customer states doors are hard to open and close	\$ 0.00	0.0			
1066	Door/Gate	Hangar	Work Complete	2021-03-10 17:31	Daniel Thomas Sr.	HG- 57. The airside small hanger door is not shutting correctly.	\$ 0.00	0.0	2021-03-16 00:00	Daniel Thomas Sr.	
1067	Door/Gate	Hangar	Work Complete	2021-03-10 17:35	Daniel Thomas Sr.	HG-57. On the airfield side. The second hangar door track where the gap is. One part of the track is sticking up a little higher than the other part is. This makes the door hard to open.	\$ 0.00	0.0	2021-03-15 00:00	Daniel Thomas Sr.	
1071	Lighting	Hangar	Work Complete	2021-03-16 08:50	Michele Renfro	4D - Customer states lights are not working in the hangar. Work order 117 was closed in December 2019 stating work was complete.	\$ 0.00	0.0	2021-03-12 00:00	Daniel Thomas Sr.	
1072	Door/Gate	Hangar	In Progress	2021-03-16 08:51	Michele Renfro	H13 - Tower side doors are not closing and doors are by passing each other. Customer on that side of hangar has mentioned the aircraft not being secured.	\$ 0.00	0.0			
1075	Electrical	Hangar	In Progress	2021-03-16 12:22	Michele Renfro	5E - Electrical panel needs to be worked on internally as well as replace face plate. door cut off switch.	\$ 0.00	0.0			
1092	Door/Gate	Hangar	Work Complete	2021-03-23 17:17	Daniel Thomas Sr.	HG-5- I (storage room) - door handle needs to be replaced with outdoor handle	\$ 0.00	0.0	2021-03-23 00:00	Daniel Thomas Sr.	
1097	Electrical	Hangar	Work Complete	2021-04-01 09:21	Daniel Thomas Sr.	HG-13 Mr. Jack (hg2a 706-573-1423) called me and reported they had no power in the EAA part of hangar 13. Circuit breaker # 5 is bad and has to be replaced.	\$ 0.00	0.0	2021-03-31 00:00	Daniel Thomas Sr.	
1098	Wildlife	Hangar	Work Complete	2021-04-01 10:01	Daniel Thomas Sr.	Hg 11-2. Mr.Desport came to me (Daniel) a showed me this hangar bay and where there was a lot of bird mess and small feathers on the floor. He requested to have this cleaned up because the aircraft that belongs in this hangar was coming back and will be parked in this hangar again.	\$ 0.00	0.0	2021-04-01 00:00	Daniel Thomas Sr.	

1104	Door/Gate	Hangar	Work Complete	2021-04-05 11:13	Ernie Kelly	Rolling doors on Hangar 11, Bay 3, are hanging up and are difficult to open. The number 1 door (full travel, with lock and hasp) hangs up about halfway across. The metal frame hits the ground and rail and will stop the door if you are not moving very quickly. The number 2 door (middle section) will stop roughly one-third to one-half way between fully closed and fully open. Both doors hang up whether opening or closing. It's difficult for many of our members to open the doors alone. Impossible for some.	\$ 0.00	0.0	2021-04-06 00:00	Daniel Thomas Sr.		
1107	Door/Gate	Hangar	Work Complete	2021-04-06 19:24	Michele Renfroe	5E - Add a Childproof cover to the inside handle of the door to keep from accidentally locking the handle. The hangar has a combo lock on the door to keep it secured.	\$ 0.00	0.0	2021-04-06 00:00	Daniel Thomas Sr.		
1108	Door/Gate	Hangar	Work Complete	2021-04-06 19:25	Michele Renfroe	5F - Add a Childproof cover to the inside handle of the door to keep from accidentally locking the handle. The hangar has a combo lock on the door to keep it secured.	\$ 0.00	0.0	2021-04-06 00:00	Daniel Thomas Sr.		
1109	Door/Gate	Hangar	In Progress	2021-04-06 19:25	Michele Renfroe	8D - Hangar door stop is completely gone. Please add angle iron to end of door track so door does not run off track when opening.	\$ 0.00	0.0				
1110	Door/Gate	Hangar	Work Complete	2021-04-06 19:26	Michele Renfroe	8F - Hangar door stop is completely gone. Please add angle iron to end of door track so door does not run off track when opening.	\$ 0.00	0.0	2021-04-08 00:00	Daniel Thomas Sr.		
1111	Door/Gate	Hangar	In Progress	2021-04-06 19:26	Michele Renfroe	7A - Metal on door l-beams need to be trimmed back to keep the door from rubbing and slowing down the door opening. 1st door still extremely hard to open.	\$ 0.00	0.0				
1112	Door/Gate	Hangar	In Progress	2021-04-07 09:51	Amber Clark	12-Need new seals on bottoms of doors large gap on opposite side of ramp, The ramp-side doors have a smaller gap. Wind and rain are blowing debris in hangar and causing standing water. needs seals along doors where gaps appear to prevent bird entry.	\$ 0.00	0.0				
1113	Other	Hangar	In Progress	2021-04-07 09:55	Amber Clark	12-Pin holes in side wall of hangars. Witnessed some on right side wall (if facing hangar from ramp) close to ramp-side doors. Please look at all walls to determine if there are any additional pin holes.	\$ 0.00	0.0				
1114	Lighting	Hangar	In Progress	2021-04-07 09:57	Amber Clark	12-Two lights in the middle of hangar closer to the ramp-side doors inop. The smaller light needs to be replaced with a light that matches the rest of the hangar lighting. The other light needs to be troubleshoot to determine why it is out and needs to be fixed as necessary	\$ 0.00	0.0				
1115	Electrical	Hangar	In Progress	2021-04-07 10:00	Amber Clark	12-Lights go off in office after being turned on for a period of time. Do not believe the breaker is tripping. Could not confirm. Tenant believes there may be a short in wiring. May want to look at upgrading or adding electrical circuits, tenant stated that a fan plugged in the hangar will trip the breaker.	\$ 0.00	0.0				
1116	Door/Gate	Hangar	In Progress	2021-04-07 12:11	Amber Clark	12-Doors are sagging. Inflatable wheels may need to be replaced. also replace metal wheels, check tracks and concrete as well	\$ 0.00	0.0				
1117	Other	Hangar	In Progress	2021-04-07 12:13	Amber Clark	12-Tenant states water is seeping up from the ground in hangar. I recommend first completing door seals and roof leak repairs first to get a better idea of where the water is seeping in at.	\$ 0.00	0.0				
1118	Door/Gate	Hangar	In Progress	2021-04-07 12:17	Amber Clark	57-Hangar doors are very hard to open. Tenant recommends to replace wheels and wheel bearings. Wheel and bearings should be properly greased. Please take off a wheel from landside hangar door to determine correct size and type of bearings.	\$ 0.00	0.0				
1125	Door/Gate	Hangar	Work Complete	2021-04-09 19:41	Daniel Thomas Sr.	8E - Hangar door stop is completely gone. Please add angle iron to the end of the door track so the door does not run off track when opening.	\$ 0.00	0.0	2021-04-09 00:00	Daniel Thomas Sr.		
1129	Door/Gate	Hangar	Work Complete	2021-04-15 17:58	Michele Renfroe	3A - Customer called and stated it looks like the door to his hangar has been hit in the past month he was not here. Stated that the locking latch looks to be bent back and screws are missing. Can you please take a look at both the door and latch.	\$ 0.00	0.0	2021-05-05 18:35	Daniel Thomas Sr.		

113 3	Holes	Hangar	In Progress	2021-04-23 12:12	Michael Henley	Hanger 18-A leaking roof. blue x taped on floor marks the spot. Water source is two holes in roof in hanger to the right, water runs down channel to my hanger.	\$ 0.00	0.0				
114 4	Wildlife	Hangar	In Progress	2021-04-27 14:45	Michele Renfro	6E - Customer called and stated pigeons present and active in his hangar. They could be coming in from another hangar bay since the walls do not go all the way up in the hangar.	\$ 0.00	0.0				
114 8	Holes	Hangar	In Progress	2021-04-30 16:42	Michael Henley	Hanger 18-A leaking roof, blue x taped on floor marks the spot. Water source is two holes in roof in hanger to the right, water runs down channel to my hanger.	\$ 0.00	0.0				
115 0	Wildlife	Hangar	In Progress	2021-05-05 13:28	Michele Renfro	H13 - Netting needs to be completed in the rest of the hangar to keep out the birds. Birds have started roosting above the current netting.	\$ 0.00	0.0				
115 1	Wildlife	Hangar	In Progress	2021-05-05 13:29	Michele Renfro	15B - Customer states that pigeons are still getting in through the small opening that is attached in the photo.	\$ 0.00	0.0				
115 5	Door/Gate	Hangar	In Progress	2021-05-05 13:33	Michele Renfro	5D - Flightways employee stated that the guide wire on the scissor door is off the roller and might need adjusting.	\$ 0.00	0.0				
115 6	Door/Gate	Hangar	In Progress	2021-05-05 13:34	Michele Renfro	5A - Striker plate has fallen off new door handle. needs to be screwed back on to the door jam	\$ 0.00	0.0				
119 4	FOD	Hangar	Work Complete	2021-05-19 11:47	Michele Renfro	8D - customer asked if the sweeper could be ran in front of hangar. He stated a lot if loose gravel is present.	\$ 0.00	0.0	2021-06-01 17:34	Daniel Thomas Sr.		
120 1	Wind Cone	Hangar	In Progress	2021-05-25 15:39	Michele Renfro	Helicopter hangar wind sock is falling off the pole and light on top of wind sock needs to be replaced it is burned out.	\$ 0.00	0.0				
120 2	Holes	Hangar	In Progress	2021-05-25 15:40	Michele Renfro	21A - Hole in Roof, Walls and door that needs to be filled. This hangar has just come available so it is empty to do the work. Photos attached.	\$ 0.00	0.0				
120 3	Roof	Hangar	In Progress	2021-05-25 15:40	Michele Renfro	18F Office - false roof is starting to fall down as well as the tiles and insulation. Hole open at back where air conditioner was installed at one time.	\$ 0.00	0.0				
120 4	Door/Gate	Hangar	In Progress	2021-05-25 15:41	Michele Renfro	14C - 1st door on left needs a stop added to make the hangar secure. Door roll freely when combo locked together due to not have a stop on the 1st or 2nd door.	\$ 0.00	0.0				
122 2	Door/Gate	Hangar	In Progress	2021-06-01 15:47	Michele Renfro	1C - hangar door stops need to be extended so doors don't overlap when opening.	\$ 0.00	0.0				
122 3	Door/Gate	Hangar	In Progress	2021-06-01 15:48	Michele Renfro	1C - Handles need to be replaced to open doors. One fell off and the other is loose.	\$ 0.00	0.0				
122 4	Roof	Hangar	In Progress	2021-06-01 15:49	Michele Renfro	17A - Holes in roof need to be repaired.	\$ 0.00	0.0				
122 7	Other	Hangar	In Progress	2021-06-01 15:51	Michele Renfro	7D - hangar tenant has moved out and hangar needs to be cleaned	\$ 0.00	0.0				
124 2	Lighting	Hangar	In Progress	2021-06-15 18:02	Michele Renfro	5C - Customer stated that outside lighting is not working. Looks like water has filled up the housing and blown the interior led light.	\$ 0.00	0.0				
124 6	Other	Hangar	In Progress	2021-06-17 21:50	Michele Renfro	1B - Customer called and stated the bottom rail has came loose and is making it hard to close the doors.	\$ 0.00	0.0				
128 0	Lighting	Hangar	In Progress	2021-07-20 08:30	Michele Renfro	11 bay 4 Office - lights only have 1 illumined for the whole office. Pictures attached.	\$ 0.00	0.0				
128 1	Lock	Hangar	In Progress	2021-07-20 08:30	Michele Renfro	11 bay 4 - office lock is not hitting the striker plate so you can pull on the knob when locked and it will open. Picture attached.	\$ 0.00	0.0				
129 9	Other	Hangar	In Progress	2021-07-28 17:43	Michele Renfro	16D - Customer states water is coming in from the outside bottom of the wall on the runway side. Right side looking in at the bottom of the hangar wall as well as a small roof leak on the right side above the wing area.	\$ 0.00	0.0				

1310	Wildlife	Hangar	In Progress	2021-08-04 19:42	Terry Echols	Work request # 502 was submitted and approved June 1. 2021. As of today it has been over a month and no action take, please advise me of the status of this work order, and why no action has been taken. I have cleaned pigeon crap off my plane and floor to many times, I thought the hangar rent increase was to bring our hangers up from the minimum standards, looks like this has not been the case.	\$ 0.00	0.0				
1313	Electrical	Hangar	In Progress	2021-08-12 18:31	Michele Renfro	21H - Customer states that the timer light switch is connected to the power outlet so when you have anything plugged into the wall outlet when the timer for the light goes off the outlet goes off. Needs to be wired and separated from the timer light switch.	\$ 0.00	0.0				
1314	Wildlife	Hangar	In Progress	2021-08-12 18:31	Michele Renfro	5H - 2 rats found in the hangar. please contact pest control company to check bait boxes. Photos are attached that the customer sent over.	\$ 0.00	0.0				