

City of Calexico
Standards for Abatement
Fire Prevention Services, Inc.

- 1. Trash, rubbish, debris, dead vegetation and other combustible materials which create a fire hazard/nuisance must be removed from the entire property and properly disposed of.**
- 2. Properties of one (1) acre or less shall be cleared in their entirety.**
- 3. Properties of more than one (1) acre shall have a minimum of one hundred (100) feet clearance from structures and fifty (50) feet around the perimeter and through the center.**
- 4. Roadways and/or driveways shall have a vertical clearance of thirteen and one half (13 1/2) feet above the road surface and ten (10) feet back on each side.**
- 5. Mature trees must be trimmed to six (6) feet above the ground or as approved by the Agency and must be cut back at least ten (10) feet from chimneys. All leaves, bark and other debris must be removed from the ground and roof .**