

Evaluation Report DH-WC
December 21, 2020

Product Description: Double Hung Wood Window, Weight and Chain, Impact

Manufacturer: Oliveri Millworks (OWW LLC), 3001 Tuxedo Ave., West Palm Beach, FL

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 7th Edition (2020) Florida Building Code including the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Approval drawing DH-WC, signed and sealed by Lucas A. Turner, P.E
- 3) Test Reports TEL 03601161/2/3/4 and 04761421 (signed/sealed by William Shelton, P.E.) from Testing Evaluation Laboratories, Plant City, FL, with Testing Performed: TAS 201/202/203 1994
- 4) Supplemental Calculations to support DH-WC, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document DH-WC.

Limitations of Use: This product:

- May be used up to the sizes and configurations, with glazing or panel types with maximum sizes as shown in DH-WC
- Achieves design pressures as indicated in DH-WC
- Is Large Missile Impact Resistant and does not require the use of shutters
- May be used in the High Velocity Hurricane Zone
- Requires Saflex HP Interlayer per Miami-Dade NOA #20-0622.02, Saflex CP (Storm) Interlayer per Miami-Dade NOA #20-0622.03, or Kuraray Sentryglas per Miami-Dade NOA #20-0915.19, as indicated in DH-WC.
- Requires wood framing as indicated in DH-WC

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Oliveri Millworks or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



22

12/21/2020
Lucas A. Turner, P.E.
FL PE #58201