

Evaluation Report 1000-Door
December 21, 2020

Product Description: Series 1000 Wood and Wood Clad Mahogany Outswing Glazed and Solid Doors, with or without Sidelites and/or Transom

Manufacturer: Oliveri Millworks (OWW LLC), 3001 Tuxedo Ave., West Palm Beach, FL

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 7th Edition (2020) Florida Building Code including the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Approval drawing 1000-Door, signed and sealed by Lucas A. Turner, P.E
- 3) Test Reports ESP013300P/-1/-2 and ESP013599P/-1 (signed/sealed by Ramesh Patel, P.E.) from Element Materials Technology, Wausau, WI, and TEL 03602027 (signed/sealed by William Shelton, P.E.), from Testing Evaluation Laboratories, Plant City, FL, with Testing Performed: TAS 201/202/203 1994
- 4) Supplemental Calculations to support 1000-Door, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document 1000-Door.

Limitations of Use: This product:

- May be used up to the sizes and configurations, with glazing or panel types with maximum sizes as shown in 1000-Door
- Achieves design pressures of up to +60/-60 psf
- Is Large Missile Impact Resistant and does not require the use of shutters
- May be used in the High Velocity Hurricane Zone
- Requires Saflex CP (Storm) Interlayer with PET core per Miami-Dade NOA #20-0622.03 in 7/16 lami and I.G. lami options. In 9/16 lami option, requires either Saflex clear or color PVB interlayer per Miami-Dade NOA #20-0622.01 or Kuraray Sentryglas per Miami-Dade NOA #20-0915.19, with lami as indicated in 1000-Door.
- Requires wood framing as indicated in 1000-Door

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Oliveri Millworks or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



22

12/21/2020
Lucas A. Turner, P.E.
FL PE #58201