



# Initial Fuel Storage Tank Evaluation Above ground tanks

Name \_\_\_\_\_

Address \_\_\_\_\_

Town \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_

Telephone (     ) \_\_\_\_\_ Email \_\_\_\_\_

## Tank

Tank location? \_\_\_\_\_

If outside, is the tank protected by an enclosure? .....  N/A .....  Yes .....  No

Is the tank installed with full secondary containment? .....  Yes .....  No

Tank size? \_\_\_\_\_ gallons                      Tank height? \_\_\_\_\_ inches

Tank type? \_\_\_\_\_

Tank exterior, including legs and pad or foundation satisfactory? ...  Yes .....  No

Evidence of excessive external corrosion? .....  Yes .....  No

Tank securely mounted in flood prone areas? .....  N/A .....  Yes .....  No

Any evidence of oil spills? .....  Yes .....  No

Tank checked for oil staining? .....  Yes .....  No

Tank gauge properly installed? .....  Yes .....  No

Tank bottom at least 6 inches off the ground? .....  Yes .....  No

Tank at least 5 feet from open flame or fuel burning appliance? .....  Yes .....  No

Unused openings properly plugged? .....  Yes .....  No

Comments: \_\_\_\_\_

## Tank Contents

Amount of oil in the tank? \_\_\_\_\_ gallons

Is there water in the tank? .....  Yes .....  No

If yes, how many inches? \_\_\_\_\_ inches

Comments: \_\_\_\_\_

## Fill Pipe

Pipe size \_\_\_\_\_

Pitched toward tank? .....  Yes .....  No

Proper material? .....  Yes .....  No

In good condition? .....  Yes .....  No

Positioned to avoid buildup of water and snow? .....  Yes .....  No

Fill cap (including gasket if applicable) in place/in good condition? ...  Yes .....  No

Properly piped, outside at least 2 feet from windows or openings?  Yes .....  No

Fill properly identified? .....  Yes .....  No

Old fill pipe removed? .....  N/A .....  Yes .....  No

Comments: \_\_\_\_\_

## Vent Pipe

- Proper size? .....  Yes .....  No
- Pitched toward tank? .....  Yes .....  No
- Proper material? .....  Yes .....  No
- In good condition? .....  Yes .....  No
- Vent visible from fill? .....  Yes .....  No
- Vent alarm installed? .....  Yes .....  No
- Vent cap in place and in good condition? .....  Yes .....  No
- Positioned to avoid buildup of water and snow? .....  Yes .....  No
- Higher than fill pipe? .....  Yes .....  No
- Properly piped, outside at least 2 feet from windows or openings ..  Yes .....  No
- Properly piped, outside at least 5 feet from appliance air inlets or flue gas outlets? ....  Yes ...  No
- Comments: \_\_\_\_\_

## Oil Lines

- Line size? \_\_\_\_\_
- Proper material? .....  Yes .....  No
- Oil lines encapsulated? .....  Yes .....  No
- Working shutoff at tank? .....  Yes .....  No
- OSV installed? .....  Yes .....  No
- Lines properly connected back to burner? .....  Yes .....  No
- Outside exposed lines insulated? .....  NA .....  Yes .....  No
- Any compression fittings? .....  Yes .....  No
- Oil filter properly installed? .....  Yes .....  No
- Fusible valves properly located? .....  Yes .....  No
- System checked for oil leaks? .....  Yes .....  No
- Comments: \_\_\_\_\_

**This tank is acceptable for fuel delivery..**  Yes.....  No

This tank **will be** acceptable for delivery **once** the following defects are **corrected**:

- \_\_\_\_\_
- \_\_\_\_\_
- \_\_\_\_\_
- \_\_\_\_\_
- \_\_\_\_\_
- \_\_\_\_\_

Inspected by: \_\_\_\_\_ Date: \_\_\_\_\_

Company: \_\_\_\_\_ Phone: \_\_\_\_\_

Town: \_\_\_\_\_